

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							Intercept or Cardinal	Foam or Dura****				
horizontal slider	1120	6040	3/4"	1/8	5/32	-	-	-	33	27	11/03/08	<a href="#">TL08-677</a>
				1/8	3/16	-	-	-	32	27	11/03/08	<a href="#">TL08-678</a>
				1/8	1/4	-	-	-	35	-	08/04/88	<a href="#">TL88-194</a>
				1/8	LAM	-	-	-				
vertical slider	1520	4060	3/4"	1/8	5/32	-	-	-	30	24	11/04/08	<a href="#">TL08-683</a>
				1/8	3/16	-	-	-	30	25	11/04/08	<a href="#">TL08-682</a>
				1/8	1/4	-	-	-				
picture window ( slider frame )	1170	47" x 59"	3/4"	-	-	-						
picture window	920PW	6040	1"	1/8	5/32	-	-	-	31	24	11/03/08	<a href="#">TL08-674</a>
				1/8	3/16	-	-	-	33	26	11/03/08	<a href="#">TL08-676</a>
				1/8	1/4	-	-	-	33	27	11/03/08	<a href="#">TL08-675</a>
				1/8	LAM	-	-	-				
casement	920FC	3050	1"	1/8	5/32	-	-	-	32	26	11/04/08	<a href="#">TL08-679</a>
				1/8	3/16	-	-	-	32	26	11/04/08	<a href="#">TL08-681</a>
				1/8	1/4	-	-	-	32	26	11/04/08	<a href="#">TL08-680</a>
				1/8	LAM	-	-	-				
awning	920FA	using 920FC tests	1"	1/8	5/32	-	-	-	32	26	11/04/08	<a href="#">TL08-679</a>
				1/8	3/16	-	-	-	32	26	11/04/08	<a href="#">TL08-681</a>
				1/8	1/4	-	-	-	32	26	11/04/08	<a href="#">TL08-680</a>
				1/8	LAM	-	-	-				
picture window ( radius )	R-20	47" x 59"	1"	-	-	-						
sliding door	420	79" x 79"	1"	-	-	-						