

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
horizontal slider	6110 6111 6130 6130J 6170	59" x 47"	3/4"	1/8	1/8	-	x	<--	29	24	12/14/22	TL22-269
				1/8	3/16	-	x	<--	32	28	12/14/22	TL22-270
				1/8	LAM	-	-->	x	34	29	12/14/22	TL22-271
				3/16	3/16	-	x	<--	29	26	04/25/23	TL23-148
				3/16	1/4	-	-->	x	30	27	04/12/23	TL23-119
				1/4	1/4	-	-->	x	31	27	04/12/23	TL23-120
				1/4	LAM	-	-->	x	32	29	04/12/23	TL23-130
vertical slider	6210 6211 6230 6230J 6270	47" x 59"	3/4"	1/8	1/8	-	x	<--	28	23	12/12/22	TL22-245
				1/8	3/16	-	x	<--	32	27	12/12/22	TL22-246
				1/8	LAM	-	-->	x	33	28	12/12/22	TL22-247
				3/16	3/16	-	x	<--	29	27	04/26/23	TL23-160
				3/16	1/4	-	-->	x	30	28	04/26/23	TL23-161
				1/4	1/4	-	-->	x	31	28	04/11/23	TL23-111
				1/4	LAM	-	-->	x	32	29	04/11/23	TL23-110
fixed - slider frame	6310 6311 6331 6331J 6370	47" x 59"	3/4"	1/8	1/8	-	x	<--	27	22	12/13/22	TL22-254
				1/8	3/16	-	x	<--	32	26	12/13/22	TL22-256
				1/8	LAM	-	-->	x	32	26	12/13/22	TL22-258
				3/16	3/16	-	x	<--	31	27	04/10/23	TL23-106
				3/16	1/4	-	-->	x	33	30	04/10/23	TL23-107
				1/4	1/4	-	-->	x	32	29	04/10/23	TL23-108
				1/4	LAM	-	-->	x	34	30	04/11/23	TL23-109
fixed - step frame	6340 6341 6330 6330J	47" x 59"	1"	1/8	1/8	-	x	<--	27	22	12/12/22	TL22-249
				1/8	3/16	-	x	<--	31	24	12/12/22	TL22-248
				1/8	LAM	-	-->	x	32	25	12/12/22	TL22-250
				3/16	3/16	-	x	<--	30	24	04/10/23	TL23-101
				3/16	1/4	-	x	<--	34	29	04/10/23	TL23-102
				1/4	1/4	-	x	<--	32	27	04/10/23	TL23-103
				1/4	LAM	-	-->	x	35	28	04/10/23	TL23-104

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
fixed - FA/FC match 6350 & 6351 Going obsolete 10/06/26 CTB+ v2.1.22	6350 6351 6360 6375	47" x 59"	7/8"	1/8	1/8	-	x	<--	28	23	12/13/22	TL22-251
				1/8	3/16	-	x	<--	32	25	12/13/22	TL22-252
				1/8	LAM	-	-->	x	34	27	12/13/22	TL22-253
				3/16	3/16	-	x	<--	31	26	04/10/23	TL23-097
				3/16	1/4	-	x	<--	33	29	04/10/23	TL23-098
				1/4	1/4	-	x	<--	32	26	04/10/23	TL23-099
				1/4	LAM	-	-->	x	36	29	04/10/23	TL23-100
picture window - CADG 8350 Starting 10/06/26 CTB+ V2.1.22	8350	47" x 59"	7/8"	1/8	1/8	-	x	<--	28	23	05/10/23	TL23-193R2
				1/8	3/16	-	x	<--	33	27	05/10/23	TL23-194R2
				1/8	LAM	-	-->	x	34	28	05/10/23	TL23-195R2
				5/32	5/32	-	x	<--	30	26	05/06/25	TL25-093
				3/16	3/16	-	x	<--	32	27	05/10/23	TL23-196R2
				3/16	1/4	-	x	<--	34	29	05/10/23	TL23-197R2
				1/4	1/4	-	x	<--	32	27	05/10/23	TL23-198R2
				1/4	LAM	-	-->	x	36	30	05/10/23	TL23-199R2
picture window - CADG (accessory groove) 8354 Starting 10/06/26 CTB+ V2.1.22	8354	47" x 59"	7/8"	1/8	1/8	-	x	<--	29	24	05/10/23	TL23-200R1
				1/8	3/16	-	x	<--	33	27	05/10/23	TL23-201R1
				1/8	LAM	-	-->	x	33	28	05/10/23	TL23-202R1
				5/32	5/32	-	x	<--	31	26	05/07/25	TL25-107
				3/16	3/16	-	x	<--	34	29	05/10/23	TL23-203R1
				3/16	1/4	-	x	<--	34	29	05/11/23	TL23-204R1
				1/4	1/4	-	x	<--	32	27	05/11/23	TL23-205R1
				1/4	LAM	-	-->	x	35	30	05/11/23	TL23-206R1

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
awning (flat sash) 6410T & 6411T Going obsolete 10/06/26 CTB+ v2.1.22	6410T 6411T 6430T 6470T	59" x 24"	7/8"	1/8	1/8	-	x	<--	28	24	12/14/22	TL22-262R2
				1/8	3/16	-	x	<--	32	27	12/14/22	TL22-263R2
				1/8	LAM	-	-->	x	31	27	12/14/22	TL22-266R2
				3/16	3/16	-	x	<--	31	27	04/26/22	TL23-158R1
				3/16	1/4	-	x	<--	32	28	04/11/23	TL23-113R1
				1/4	1/4	-	x	<--	32	28	04/11/23	TL23-114R1
				1/4	LAM	-	-->	x	32	29	04/11/23	TL23-116R1
awning 8420T2 Starting 10/06/26 CTB+ V2.1.22	8420T2	59" x 24"	7/8"	1/8	1/8	-	x	<--	31	26	11/08/23	TL23-431
				1/8	3/16	-	x	<--	35	29	11/07/23	TL23-401
				1/8	LAM	-	-->	x	34	29	11/07/23	TL23-402
				3/16	3/16	-	x	<--	32	26	11/07/23	TL23-403
				3/16	1/4	-	x	<--	34	29	11/07/23	TL23-404
				1/4	1/4	-	x	<--	32	28	11/07/23	TL23-405
				1/4	LAM	-	-->	x	34	29	11/07/23	TL23-406
			1 1/8"	1/8	1/8	-	x	<--	32	24	11/08/23	TL23-424
				1/8	3/16	-	x	<--	36	28	11/08/23	TL23-425
				1/8	LAM	-	-->	x	36	28	11/08/23	TL23-426
				3/16	3/16	-	x	<--	33	26	11/08/23	TL23-427
				3/16	1/4	-	x	<--	36	30	11/08/23	TL23-428
				1/4	1/4	-	x	<--	35	28	11/08/23	TL23-429
				1/4	LAM	-	-->	x	36	29	11/08/23	TL23-430
awning (accessory groove) 8440T2 Starting 10/06/26 CTB+ V2.1.22	8440T2	59" x 24"	7/8"	1/8	1/8	-	x	<--	31	25	11/08/23	TL23-411
				1/8	3/16	-	x	<--	35	29	11/07/23	TL23-409
				1/8	LAM	-	-->	x	35	30	11/08/23	TL23-410
				3/16	3/16	-	x	<--	31	26	11/08/23	TL23-412
				3/16	1/4	-	x	<--	35	30	11/08/23	TL23-413
				1/4	1/4	-	x	<--	33	29	11/08/23	TL23-416
				1/4	LAM	-	-->	x	35	30	11/08/23	TL23-415
			1 1/8"	1/8	1/8	-	x	<--	32	25	11/08/23	TL23-417
				1/8	3/16	-	x	<--	35	27	11/08/23	TL23-418
				1/8	LAM	-	-->	x	36	29	11/08/23	TL23-419
				3/16	3/16	-	x	<--	33	26	11/08/23	TL23-420
				3/16	1/4	-	x	<--	35	29	11/08/23	TL23-421
				1/4	LAM	-	-->	x	36	29	11/08/23	TL23-423

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							rigid	non-rigid				
							Intercept / Cardinal	Foam / TP-S / Dura****				
casement (flat sash) 6510T & 6511T Going obsolete 10/06/26 CTB+ v2.1.22	6510T 6511T 6530T 6570T	24" x 59"	7/8"	1/8	1/8	-	x	<--	30	24	12/12/22	TL22-242
				1/8	3/16	-	x	<--	32	27	12/12/22	TL22-241
				1/8	LAM	-	-->	x	34	28	12/12/22	TL22-243
				3/16	3/16	-	x	<--	31	26	04/26/22	TL23-159
				3/16	1/4	-	x	<--	31	28	04/10/23	TL23-094
				1/4	1/4	-	x	<--	32	28	04/10/23	TL23-095
				1/4	LAM	-	-->	x	34	30	04/10/23	TL23-096
casement 8520T2 Starting 10/06/26 CTB+ V2.1.22	8520T2	24" x 59"	7/8"	1/8	1/8	-	x	<--	30	24	11/09/23	TL23-432
				1/8	3/16	-	x	<--	35	29	11/09/23	TL23-433
				1/8	LAM	-	-->	x	37	30	11/09/23	TL23-434
				3/16	3/16	-	x	<--	31	25	11/09/23	TL23-435
				3/16	1/4	-	x	<--	36	30	11/09/23	TL23-436
				1/4	1/4	-	x	<--	33	28	11/09/23	TL23-437
				1/4	LAM	-	-->	x	36	29	11/09/23	TL23-438
			1 1/8"	5.7 mm	0.5 mm	3.1 mm	-->	TP-S	36	30	11/15/24	TL24-191
				1/8	1/8	-	x	<--	31	24	11/09/23	TL23-440
				1/8	3/16	-	x	<--	37	29	11/09/23	TL23-441
				1/8	LAM	-	-->	x	38	30	11/09/23	TL23-442
				3/16	3/16	-	x	<--	34	25	11/09/23	TL23-443
				3/16	1/4	-	x	<--	37	30	11/09/23	TL23-444
				1/4	1/4	-	x	<--	35	28	11/09/23	TL23-445
				1/4	LAM	-	-->	x	38	30	11/09/23	TL23-446
casement (accessory groove) 8540T2 Starting 10/06/26 CTB+ V2.1.22	8540T2	24" x 59"	7/8"	1/8	1/8	-	x	<--	31	25	11/09/23	TL23-447
				1/8	3/16	-	x	<--	35	29	11/09/23	TL23-448
				1/8	LAM	-	-->	x	37	30	11/09/23	TL23-450
				3/16	3/16	-	x	<--	32	25	11/09/23	TL23-451
				3/16	1/4	-	x	<--	35	30	11/09/23	TL23-452
				1/4	1/4	-	x	<--	33	28	11/10/23	TL23-454
				1/4	LAM	-	-->	x	35	28	11/10/23	TL23-456
			1 1/8"	1/8	1/8	-	x	<--	31	24	11/10/23	TL23-457
				1/8	3/16	-	x	<--	36	28	11/10/23	TL23-459
				1/8	LAM	-	-->	x	37	29	11/10/23	TL23-460
				3/16	3/16	-	x	<--	34	26	11/10/23	TL23-461
				3/16	1/4	-	x	<--	37	30	11/10/23	TL23-462
				1/4	1/4	-	x	<--	35	29	11/10/23	TL23-463
				1/4	LAM	-	-->	x	37	29	11/10/23	TL23-464