

STC Ratings

Rev: 12/01/2020 by K.Pim

Operating Style	Series Numbers	Unit		Panel Glass 3	Spacer		STC	OITC	Test Date	Test Number
		Glass 1	Glass 2		Intercept or Cardinal	Foam or Dura****				
	7120 size tested 6040	1/8	1/8	1/8	-	-	41	30	08/10/99	TL99-296
		1/8	1/8	3/16	-	-	44	33	08/10/99	TL99-295
		1/8	1/8	LAM	-	-	45	35	08/10/99	TL99-294
		1/8	3/16	3/16	-	-	46	36	08/09/99	TL99-289
		1/8	3/16	1/4	-	-	46	37	08/09/99	TL99-290
		1/8	LAM	3/16	-	-	46	37	08/10/99	TL99-291
		1/8	LAM	LAM	-	-	47	38	08/10/99	TL99-292
		LAM	LAM	LAM	-	-	47	38	08/10/99	TL99-293
	7220 size tested 4060	1/8	1/8	1/8	-	-	41	30	08/11/99	TL99-307
		1/8	1/8	3/16	-	-	44	33	08/11/99	TL99-308
		1/8	1/8	LAM	-	-	45	33	08/12/99	TL99-309
		1/8	3/16	3/16	-	-	45	33	08/12/99	TL99-313
		1/8	3/16	1/4	-	-	46	34	08/12/99	TL99-314
		1/8	LAM	3/16	-	-	45	34	08/12/99	TL99-311
		1/8	LAM	LAM	-	-	46	36	08/12/99	TL99-310
	7320 size tested 6040	1/8	1/8	1/8	-	-	40	30	08/10/99	TL99-297
		1/8	1/8	3/16	-	-	42	32	08/10/99	TL99-298
		1/8	1/8	LAM	-	-	44	32	08/10/99	TL99-299
		1/8	3/16	3/16	-	-	44	35	08/13/99	TL99-318
		1/8	3/16	1/4	-	-	45	37	08/13/99	TL99-320
		1/8	LAM	3/16	-	-	45	36	08/12/99	TL99-317
		1/8	LAM	LAM	-	-	47	37	08/12/99	TL99-316
		3/16	3/16	3/16	-	-	42	34	07/26/12	TL12-413
LAM	LAM	LAM	-	-	48	38	08/12/99	TL99-315		
	7420 size tested 4030	1/8	1/8	1/8	-	-	40	31	03/26/01	TL01-287
		1/8	1/8	3/16	-	-	42	31	03/26/01	TL01-288
		1/8	1/8	LAM	-	-	42	31	03/26/01	TL01-289
		1/8	3/16	3/16	-	-	43	33	03/27/01	TL01-293
		1/8	3/16	1/4	-	-	43	34	03/27/01	TL01-294
	7520 size tested 3050	1/8	1/8	1/8	-	-	40	31	08/11/99	TL99-300
		1/8	1/8	3/16	-	-	43	34	08/11/99	TL99-301
		1/8	1/8	LAM	-	-	44	36	08/11/99	TL99-302
		1/8	3/16	3/16	-	-	44	35	08/11/99	TL99-305
		1/8	3/16	1/4	-	-	44	37	08/11/99	TL99-306
		1/8	LAM	3/16	-	-	44	37	08/11/99	TL99-304
		1/8	LAM	LAM	-	-	45	37	08/11/99	TL99-303