



STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
horizontal slider 	8120 8130 8170 size tested 6040	1/8	1/8	-	-	29	22	4/19/07	TL07-271
		1/8	3/16	-	-				
		1/8	5/32	-	-	33	27	4/9/07	TL07-270
		3/16	1/8	-	-				
		5/32	3/16	-	-	33	26	4/10/07	TL07-276
		1/8	1/4	-	-				
		1/4	1/8	-	-	34	27	4/9/07	TL07-273
		1/8	LAM	-	-				
		LAM	1/8	-	-	31	26	9/3/13	TL13-558
		3/16	3/16	X	<--				
		5/32	5/32			32	26	6/21/18	I4873.02
		3/16	1/4	X	<--				
5/32	1/4								
1/4	3/16								
1/4	5/32								
3/16	LAM	-	-						
5/32	LAM			35	28	4/10/07	TL07-278		
LAM	3/16								
LAM	5/32								
1/4	1/4	X	<--	30	25	6/21/18	I4873.01		
1/4	LAM	-	-						
LAM	1/4			35	29	4/10/07	TL07-277		
LAM	LAM	-	-						
				35	30	4/9/07	TL07-274		

STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
horizontal slider 	8140 <i>(accessory groove)</i> size tested using 8120 tests	1/8	1/8	-	-	29	22	4/19/07	TL07-271
		1/8	3/16	-	-	33	27	4/9/07	TL07-270
		1/8	5/32	-	-	33	26	4/10/07	TL07-276
		3/16	1/8	-	-	34	27	4/9/07	TL07-273
		5/32	3/16	X	<--	31	26	9/3/13	TL13-558
		1/8	1/4	-	-	32	26	6/21/18	I4873.02
		1/4	1/8	-	-	35	28	4/10/07	TL07-278
		1/8	LAM	-	-	30	25	6/21/18	I4873.01
		LAM	1/8	-	-	35	29	4/10/07	TL07-277
		3/16	3/16	X	<--	35	30	4/9/07	TL07-274
		5/32	5/32	-	-				
		1/4	3/16	X	<--				
1/4	5/32	-	-						
LAM	LAM	-	-						


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number		
				Intercept or Cardinal	Foam or Dura****						
double slider 	8125 size tested 6040	1/8	1/8	-	-	29	24	2/12/08	TL08-141		
		1/8	3/16						not tested	tested	
		1/8	5/32								
		3/16	1/8								
				5/32	3/16						
		1/8	1/4	-	-	32	27	2/12/08	TL08-142		
		1/4	1/8								
		1/8	LAM	-	-	33	28	2/12/08	TL08-145		
		LAM	1/8								
		3/16	3/16							not tested	tested
		5/32	5/32								
		3/16	1/4								
5/32	1/4	-	-	33	28	2/12/08	TL08-144				
1/4	3/16										
1/4	5/32										
3/16	LAM	-	-	34	29	2/12/08	TL08-146				
5/32	LAM										
LAM	3/16										
LAM	5/32										
1/4	1/4							not tested	tested		
1/4	LAM	-	-	34	29	2/12/08	TL08-147				
LAM	1/4										
LAM	LAM	-	-	34	30	2/12/08	TL08-148				


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
single hung 	8220 8230 8270 size tested 4060	1/8	1/8	-	-	29	22	4/12/07	TL07-294
		1/8	3/16	-	-	33	27	4/12/07	TL07-297
		1/8	5/32	-	-			not	tested
		3/16	1/8						
		5/32	3/16						
		1/8	1/4	-	-	33	26	4/12/07	TL07-295
		1/4	1/8						
		1/8	LAM	-	-			not	tested
		LAM	1/8						
		3/16	3/16					not	tested
		5/32	5/32						
		3/16	1/4					not	tested
		5/32	1/4						
1/4	3/16								
1/4	5/32								
3/16	LAM	X	<--	33	28	10/11/18	I9316.01		
5/32	LAM								
LAM	3/16								
LAM	5/32								
1/4	1/4					not	tested		
1/4	LAM	-	-	35	29	4/12/07	TL07-299		
LAM	1/4								
LAM	LAM					not	tested		


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number		
				Intercept or Cardinal	Foam or Dura****						
single hung 	8240 <i>(accessory groove)</i> size tested using 8220 tests	1/8	1/8	-	-	29	22	4/12/07	TL07-294		
		1/8	3/16	-	-	33	27	4/12/07	TL07-297		
		1/8	5/32								
		3/16	1/8								
				5/32	3/16						
		1/8	1/4							not	tested
		1/4	1/8								
		1/8	LAM			-	-	33	26	4/12/07	TL07-295
		LAM	1/8								
		3/16	3/16							not	tested
		5/32	5/32								
		3/16	1/4							not	tested
		5/32	1/4								
1/4	3/16										
1/4	5/32										
3/16	LAM			X	<--	33	28	10/11/18	I9316.01		
5/32	LAM										
LAM	3/16										
LAM	5/32										
1/4	1/4							not	tested		
1/4	LAM			-	-	35	29	4/12/07	TL07-299		
LAM	1/4										
LAM	LAM							not	tested		

STC Ratings


Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
double hung 	8225	1/8	1/8	-	-	26	22	7/11/07	TL07-430
		1/8	3/16					not	tested
		1/8	5/32						
		3/16	1/8						
		5/32	3/16						
		1/8	1/4	-	-	28	26	7/11/07	TL07-435
	1/4	1/8							
	1/8	LAM	-	-	28	26	7/11/07	TL07-433	
	LAM	1/8							
	3/16	3/16					not	tested	
	5/32	5/32							
	3/16	1/4	-	-	28	26	7/11/07	TL07-437	
	5/32	1/4							
1/4	3/16								
1/4	5/32								
3/16	LAM					not	tested		
5/32	LAM								
LAM	3/16								
LAM	5/32								
1/4	1/4					not	tested		
1/4	LAM					not	tested		
LAM	1/4								
LAM	LAM					not	tested		

size tested
4060


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
picture window (step) 	8320 8330 8720 8730 size tested 6040	1/8	1/8	-	-	31	25	2/11/08	TL08-136	
		1/8	3/16							
		1/8	5/32							
		3/16	1/8	-	-	32	25	4/12/07	TL07-291	
		5/32	3/16							
		1/8	1/4	-	-	32	26	4/12/07	TL07-289	
		1/4	1/8							
		1/8	LAM	-	-	34	26	4/12/07	TL07-292	
		LAM	1/8							
		3/16	3/16	X	<--	30	25	6/21/18	I4873.09	
		5/32	5/32							
		3/16	1/4	X	<--	32	27	6/22/18	I4873.08	
5/32	1/4									
1/4	3/16									
1/4	5/32									
3/16	LAM	-->	X	33	28	6/22/18	I4873.07			
5/32	LAM									
LAM	3/16									
LAM	5/32									
1/4	1/4	-->	X	31	27	6/21/18	I4873.10			
1/4	LAM	-	-	34	27	4/12/07	TL07-293			
LAM	1/4									
LAM	LAM	-	-	37	30	4/10/07	TL07-280			


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
picture window (step) 	8340 (accessory groove) size tested using 8320 tests	1/8	1/8	-	-	31	25	2/11/08	TL08-136
		1/8	3/16	-	-	32	25	4/12/07	TL07-291
		1/8	5/32	-	-	32	25	4/12/07	TL07-289
		3/16	1/8	-	-	32	26	4/12/07	TL07-289
		5/32	3/16	-	-	32	26	4/12/07	TL07-292
		1/8	1/4	-	-	32	26	4/12/07	TL07-289
		1/4	1/8	-	-	32	26	4/12/07	TL07-292
		1/8	LAM	-	-	34	26	4/12/07	TL07-292
		LAM	1/8	-	-	34	26	4/12/07	TL07-292
		3/16	3/16	X	<--	30	25	6/21/18	I4873.09
		5/32	5/32	X	<--	30	25	6/21/18	I4873.09
		3/16	1/4	X	<--	32	27	6/22/18	I4873.08
		5/32	1/4	X	<--	32	27	6/22/18	I4873.08
1/4	3/16	X	<--	32	27	6/22/18	I4873.08		
1/4	5/32	X	<--	32	27	6/22/18	I4873.08		
3/16	LAM	-->	X	33	28	6/22/18	I4873.07		
5/32	LAM	-->	X	33	28	6/22/18	I4873.07		
LAM	3/16	-->	X	33	28	6/22/18	I4873.07		
LAM	5/32	-->	X	33	28	6/22/18	I4873.07		
1/4	1/4	-->	X	31	27	6/21/18	I4873.10		
1/4	LAM	-	-	34	27	4/12/07	TL07-293		
LAM	1/4	-	-	34	27	4/12/07	TL07-293		
LAM	LAM	-	-	37	30	4/10/07	TL07-280		


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
picture window (slider) 	8360	1/8	1/8	X	<--	28	22	6/22/18	I4873.05	
		8370	1/8	3/16	X	<--	32	25	6/25/20	L0963.01
	1/8		5/32							
	3/16	1/8								
			5/32	3/16						
			1/8	1/4					not	tested
			1/4	1/8						
			1/8	LAM					not	tested
			LAM	1/8						
			3/16	3/16					not	tested
			5/32	5/32						
			3/16	1/4					not	tested
			5/32	1/4						
		1/4	3/16							
		1/4	5/32							
		3/16	LAM							
		5/32	LAM	-->	X	33	29	6/21/18	I4873.03	
		LAM	3/16							
		LAM	5/32							
		1/4	1/4					not	tested	
		1/4	LAM					not	tested	
		LAM	1/4							
		LAM	LAM	-->	X	34	29	6/21/18	I4873.04	


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
awning 	8420 8430 size tested using 8520 tests	3/32	3/32					not	tested	
		1/8	1/8	-	-	31	24	4/11/07	TL07-281	
		1/8	3/16							
		1/8	5/32	-	-	34	27	4/11/07	TL07-284	
		3/16	1/8							
		5/32	3/16							
		1/8	1/4	-	-	35	27	4/11/07	TL07-285	
		1/4	1/8							
		1/8	LAM	-	-	36	28	4/11/07	TL07-286	
		LAM	1/8							
		3/16	3/16						not	tested
		5/32	5/32							
		3/16	1/4						not	tested
		5/32	1/4							
		1/4	3/16							
1/4	5/32									
3/16	LAM	-	-	37	30	4/11/07	TL07-287			
5/32	LAM									
LAM	3/16									
LAM	5/32									
1/4	1/4						not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283			
LAM	1/4									
LAM	LAM	-	-	37	31	4/11/07	TL07-288			


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number		
				Intercept or Cardinal	Foam or Dura****						
awning 	8440 <i>(accessory groove)</i> size tested using 8520 tests	3/32	3/32					not	tested		
		1/8	1/8	-	-	31	24	4/11/07	TL07-281		
		1/8	3/16								
		1/8	5/32	-	-	34	27	4/11/07	TL07-284		
		3/16	1/8								
		5/32	3/16								
		1/8	1/4	-	-	35	27	4/11/07	TL07-285		
		1/4	1/8								
		1/8	LAM	-	-	36	28	4/11/07	TL07-286		
		LAM	1/8								
		3/16	3/16							not	tested
		5/32	5/32								
		3/16	1/4							not	tested
		5/32	1/4								
		1/4	3/16								
1/4	5/32										
3/16	LAM	-	-	37	30	4/11/07	TL07-287				
5/32	LAM										
LAM	3/16										
LAM	5/32										
1/4	1/4							not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283				
LAM	1/4										
LAM	LAM	-	-	37	31	4/11/07	TL07-288				


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
casement 	8520	3/32	3/32					not	tested	
		1/8	1/8	-	-	31	24	4/11/07	TL07-281	
	8530	1/8	3/16							
		1/8	5/32	-	-	34	27	4/11/07	TL07-284	
		3/16	1/8							
		5/32	3/16							
		1/8	1/4	-	-	35	27	4/11/07	TL07-285	
		1/4	1/8							
		1/8	LAM	-	-	36	28	4/11/07	TL07-286	
		LAM	1/8							
		3/16	3/16						not	tested
		5/32	5/32							
		3/16	1/4						not	tested
		5/32	1/4							
		1/4	3/16							
1/4	5/32									
3/16	LAM	-	-	37	30	4/11/07	TL07-287			
5/32	LAM									
LAM	3/16									
LAM	5/32									
1/4	1/4						not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283			
LAM	1/4									
LAM	LAM	-	-	37	31	4/11/07	TL07-288			


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number		
				Intercept or Cardinal	Foam or Dura****						
casement 	8540 <i>(accessory groove)</i> size tested using 8520 tests	3/32	3/32					not	tested		
		1/8	1/8	-	-	31	24	4/11/07	TL07-281		
		1/8	3/16								
		1/8	5/32	-	-	34	27	4/11/07	TL07-284		
		3/16	1/8								
		5/32	3/16								
		1/8	1/4	-	-	35	27	4/11/07	TL07-285		
		1/4	1/8								
		1/8	LAM	-	-	36	28	4/11/07	TL07-286		
		LAM	1/8								
		3/16	3/16							not	tested
		5/32	5/32								
		3/16	1/4							not	tested
		5/32	1/4								
		1/4	3/16								
1/4	5/32										
3/16	LAM	-	-	37	30	4/11/07	TL07-287				
5/32	LAM										
LAM	3/16										
LAM	5/32										
1/4	1/4							not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283				
LAM	1/4										
LAM	LAM	-	-	37	31	4/11/07	TL07-288				


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
picture window (fa/fc match) 	8421 8431 8521 8531 size tested using 8520 tests	3/32	3/32					not	tested	
		1/8	1/8	-	-	31	24	4/11/07	TL07-281	
		1/8	3/16							
		1/8	5/32	-	-	34	27	4/11/07	TL07-284	
		3/16	1/8							
		5/32	3/16							
		1/8	1/4	-	-	35	27	4/11/07	TL07-285	
		1/4	1/8							
		1/8	LAM	-	-	36	28	4/11/07	TL07-286	
		LAM	1/8							
		3/16	3/16						not	tested
		5/32	5/32							
		3/16	1/4						not	tested
		5/32	1/4							
		1/4	3/16							
1/4	5/32									
3/16	LAM	-	-	37	30	4/11/07	TL07-287			
5/32	LAM									
LAM	3/16									
LAM	5/32									
1/4	1/4						not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283			
LAM	1/4									
LAM	LAM	-	-	37	31	4/11/07	TL07-288			


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
picture window (fa/fc match) 	8441 8541 (accessory groove) size tested using 8520 tests	3/32	3/32					not	tested	
		1/8	1/8	-	-	31	24	4/11/07	TL07-281	
		1/8	3/16							
		1/8	5/32	-	-	34	27	4/11/07	TL07-284	
		3/16	1/8							
		5/32	3/16							
		1/8	1/4	-	-	35	27	4/11/07	TL07-285	
		1/4	1/8							
		1/8	LAM	-	-	36	28	4/11/07	TL07-286	
		LAM	1/8							
		3/16	3/16						not	tested
		5/32	5/32							
		3/16	1/4						not	tested
		5/32	1/4							
		1/4	3/16							
1/4	5/32									
3/16	LAM	-	-	37	30	4/11/07	TL07-287			
5/32	LAM									
LAM	3/16									
LAM	5/32									
1/4	1/4						not	tested		
1/4	LAM	-	-	38	30	4/11/07	TL07-283			
LAM	1/4									
LAM	LAM	-	-	37	31	4/11/07	TL07-288			


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
sliding door 	8621	1/8	1/8	-	-	29	22	10/28/98	TL98-366	
		8631	1/8	3/16	-	-	33	27	10/28/98	TL98-371
	1/8		5/32	-	-					
	3/16		1/8	-	-					
	size tested 6068	8631	1/8	1/4	-	-	33	28	10/28/98	TL98-367
			1/4	1/8	-	-				
		8631	1/8	LAM	-	-	35	28	10/28/98	TL98-368
			LAM	1/8	-	-				
		8631	3/16	3/16	-	-	33	24	4/29/03	TL03-216
			5/32	5/32	-	-				
		8631	3/16	1/4	-	-	33	28	10/28/98	TL98-369
			5/32	1/4	-	-				
			1/4	3/16	-	-				
8631		3/16	LAM	-	-	34	29	10/28/98	TL98-370	
	5/32	LAM	-	-						
	LAM	3/16	-	-						
8631	1/4	1/4	X	<--	31	25	3/6/20	K7407.03		
	1/4	LAM	-	-			not	tested		
	LAM	1/4	-	-						
8631	LAM	LAM	-	-	35	29	10/28/98	TL98-365		
	LAM	LAM	-	-						


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number
				Intercept or Cardinal	Foam or Dura****				
sliding door 	8621F	1/8	1/8	-	-	29	22	2/18/04	TL04-165
		8631F	1/8	3/16	-	-	33	26	2/18/04
	1/8		5/32	-	-				
	3/16		1/8	-	-				
	5/32		3/16	-	-				
	size tested 6068	1/8	1/4	-	-	33	27	2/18/04	TL04-167
		1/4	1/8	-	-	33	27	2/18/04	TL04-168
		1/8	LAM	-	-				
		LAM	1/8	-	-				
		3/16	3/16	-	-	31	25	2/19/04	TL04-170
		5/32	5/32	-	-			not	tested
		3/16	1/4	-	-				
		5/32	1/4	-	-				
1/4		3/16	-	-					
1/4		5/32	-	-			not	tested	
3/16	LAM	-	-						
5/32	LAM	-	-						
LAM	3/16	-	-			not	tested		
LAM	5/32	-	-						
1/4	1/4	-	-			not	tested		
1/4	LAM	-	-			not	tested		
LAM	1/4	-	-						
LAM	LAM	-	-	-	-	34	28	2/18/04	TL04-169

STC Ratings


Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
picture window (panel transom) 	8621T 8631T	1/8	1/8	X	<--	28	22	8/7/18	I2132.01	
		1/8	3/16							
		1/8	5/32	X	<--	32	26	8/7/18	I2132.02	
		3/16	1/8							
		5/32	3/16							
		1/8	1/4	X	<--	33	26	7/11/18	I2132.03	
		1/4	1/8							
		1/8	LAM	-->	X	35	27	7/11/18	I2132.04	
		LAM	1/8							
		3/16	3/16	X	<--	30	25	7/11/18	I2132.05	
		5/32	5/32							
		3/16	1/4	X	<--	32	27	7/11/18	I2132.06	
	5/32	1/4								
	1/4	3/16								
	1/4	5/32								
	3/16	LAM	-->	X	35	29	7/11/18	I2132.07		
	5/32	LAM								
	LAM	3/16								
	LAM	5/32								
	1/4	1/4	X	<--	31	25	7/11/18	I2132.08		
	1/4	LAM	-->	X	35	30	7/11/18	I2132.09		
	LAM	1/4								
	LAM	LAM	-->	X	36	28	7/11/18	I2132.10		

size tested
6040


STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number	
				Intercept or Cardinal	Foam or Dura****					
swing door 	8642	1/8	1/8	-	-	30	24	4/6/11	TL11-199	
		8662 (inswing)	1/8	3/16	-	-	32	27	4/6/11	TL11-201
	1/8		5/32	-	-					
	3/16		1/8	-	-					
	size tested 6068	5/32	1/8	1/4	-	-	33	28	4/6/11	TL11-207
			1/4	1/8	-	-				
		5/32	1/8	LAM	-	-	33	28	4/6/11	TL11-203
			LAM	1/8	-	-				
		5/32	3/16	3/16	X	<--	30	26	3/6/20	K7407.02
			5/32	5/32	-	-	32	28	4/6/11	TL11-205
		3/16	1/4	-	-					
		5/32	1/4	-	-					
5/32		1/4	3/16	-	-					
		1/4	5/32	-	-					
5/32	3/16	LAM	-	-	33	28	4/6/11	TL11-209		
	5/32	LAM	-	-						
LAM	3/16	-	-							
LAM	5/32	-	-							
5/32	1/4	1/4	X	<--	29	26	3/6/20	K7407.02		
	1/4	LAM	-	-	33	28	4/6/11	TL11-211		
LAM	1/4	-	-							
LAM	LAM	-	-	33	28	4/6/11	TL11-213			

STC Ratings

Rev: 11/25/2020 by K.Pim

Operating Style	Series Numbers	Glass 1	Glass 2	Spacer		STC	OITC	Test Date	Test Number		
				Intercept or Cardinal	Foam or Dura****						
swing door 	8643 8663 (outswing)	1/8	1/8	-	-	30	24	4/6/11	TL11-198		
		1/8	3/16	-	-	32	27	4/6/11	TL11-200		
		1/8	5/32	-	-						
			3/16	1/8	-	-					
			5/32	3/16	-	-					
			1/8	1/4	-	-	33	28	4/6/11	TL11-206	
			1/4	1/8	-	-					
			1/8	LAM	-	-	33	28	4/6/11	TL11-202	
			LAM	1/8	-	-					
		size tested 6068	3/16	3/16	X	<--	27	24	3/5/20	K7407.01	
				5/32	5/32						
				3/16	1/4	-	-	32	28	4/6/11	TL11-204
				5/32	1/4	-	-				
			1/4	3/16	-	-					
			1/4	5/32	-	-					
			3/16	LAM	-	-	33	28	4/6/11	TL11-208	
		5/32	LAM	-	-						
		LAM	3/16	-	-						
		LAM	5/32	-	-						
		1/4	1/4	X	<--	29	26	3/5/20	K7407.01		
		1/4	LAM	-	-	33	28	4/6/11	TL11-210		
		LAM	1/4	-	-						
		LAM	LAM	-	-	33	28	4/6/11	TL11-212		